

Vision 2020 Comprehensive Plan Seminole County, Florida

Level of Service Standards for New Development

Facility	Design Storm
Retention/Detention Basins (with positive outfall)	
Sites	25 Year, 24 Hour
Subdivisions	25 Year, 24 Hour
Retention /Detention Basins	100 Year, 24 Hour
(Landlocked with no positive outfall)	(Total Retention)
Retention /Detention Basins	25 Year, 24 Hour
(Adjacent to a public right-of-way with no positive	(Total Retention)
outfall)	
Closed Drainage System (Internal to Development)	10 Year, 3 hour
Roadside Swales	10 Year, 3 hour
Arterial and Collector Streets	10 Year, Hydraulic Gradient Line
	- 1.0 feet below gutter line
Local Streets	10 Year, Hydraulic Gradient Line
	0.5 feet below gutter line
Canals	25 Years
Bridges - The design frequency may be increased if found	100 Years
necessary by the Director of the Development Review	
Department to protect upstream or downstream properties	

Additionally, Drainage Element Policies 5.1, 5.2 and 5.3 relate to standards and apply to new development.

